TURBINE FLOWMETER

USER'S MANUAL



HP-228 May 2022



107 Kitty Hawk Lane • P.O. Box 2145 • Elizabeth City, NC 27909 1-800-628-4584 • (252) 331-1997 • Fax (252) 331-2886 www.hofferflow.com email: info@hofferflow.com

NOTICE

Hoffer Flow Controls, Inc. makes no warranty of any kind with regard to this material, including, but not limited to, the implied warranties of merchantability and fitness for a particular purpose.

This manual has been provided as an aid in installing, connecting, calibrating, operating, and servicing this unit. Every precaution for accuracy has been taken in the preparation of this manual; however, Hoffer Flow Controls, Inc. neither assumes responsibility for any omissions or errors that may appear nor assumes liability for any damages that result from the use of the products in accordance with information contained in the manual.

HOFFER FLOW CONTROLS' policy is to provide a user manual for each item supplied. Therefore, all applicable user manuals should be examined before attempting to install or otherwise connect a number of related subsystems.

During installation, care must be taken to select the correct interconnecting wiring drawing. The choice of an incorrect connection drawing may result in damage to the system and/or one of the components.

Please review the complete model number of each item to be connected and locate the appropriate manual(s) and/or drawing(s). Identify all model numbers exactly before making any connections. A number of options and accessories may be added to the main instrument, which are not shown on the basic user wiring. Consult the appropriate option or accessory user manual before connecting it to the system. In many cases, a system wiring drawing is available and may be requested from Hoffer Flow Controls.

This document contains proprietary information, which is protected by copyright. All rights are reserved. No part of this document may be photocopied, reproduced, or translated to another language without the prior written consent of Hoffer Flow Controls, Inc.

HOFFER FLOW CONTROLS' policy is to make running changes, not model changes, whenever an improvement is possible. This affords our customers the latest in technology and engineering. The information contained in this document is subject to change without notice.

THIS WARRANTY IS EXPRESSLY IN LIEU OF ALL OTHER WARRANTIES, EXPRESSED OR IMPLIED, INCLUDING ANY IMPLIED WARRANTY OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE. HFC SHALL NOT BE LIABLE FOR ANY LOSS OR DAMAGE RESULTING, DIRECTLY OR INDIRECTLY, FROM THE USE OR LOSS OF USE OF THE GOODS. WITHOUT LIMITING THE GENERALITY OF THE FOREGOING, THIS EXCLUSION FROM LIABILITY EMBRACES THE PURCHASER'S EXPENSES FOR DOWNTIME OR FOR MAKING UP DOWNTIME, DAMAGES FOR WHICH THE PURCHASER MAY BE LIABLE TO OTHER PERSONS, DAMAGES TO PROPERTY, AND INJURY TO OR DEATH OF ANY PERSONS. HFC NEITHER ASSUMES NOR AUTHORIZES ANY PERSON TO ASSUME FOR IT ANY OTHER LIABILITY IN CONNECTION WITH THE SALE OR USE OF HFC'S GOODS, AND THERE ARE NO ORAL AGREEMENTS OR WARRANTIES COLLATERAL TO OR AFFECTING THE AGREEMENT. PURCHASER'S SOLE AND EXCLUSIVE REMEDY IS THE REPAIR AND/OR REPLACEMENT OF NONCONFORMING GOODS AS PROVIDED IN THE PRECEDING PARAGRAPHS. HFC SHALL NOT BE LIABLE FOR ANY OTHER DAMAGES WHATSOEVER INCLUDING INDIRECT, INCIDENTAL, OR CONSEQUENTIAL DAMAGES.

HFC 9907-B

LIMITED WARRANTY POLICY FOR HOFFER FLOW CONTROLS

HOFFER FLOW CONTROLS, INC. ("HFC") warrants HFC's Precision Series, API Series and CT Series of turbine flowmeters to be free from defects in material and workmanship under normal use and service, only if such goods have been properly selected for the service intended, properly installed and properly operated and maintained as described in the turbine flowmeter manual. Reference "turbine flowmeter manual" for specific details. This warranty shall extend for a period of five (5) years from the date of shipment to the original purchaser and covers the Precision Series, API Series and CT Series of flowmeters supplied with their standard hybrid ceramic ball bearings only. All other HFC products carry a one (1) year warranty. This warranty is extended only to the original purchaser ("Purchaser"). Purchaser's sole and exclusive remedy is the repair and/or replacement of nonconforming goods as provided in the following paragraphs.

In the event Purchaser believes the Hoffer product is defective, the product must be returned to HFC, transportation prepaid by Purchaser, within the appropriate warranty period relative to the product. If HFC's inspection determines that the workmanship or materials are defective and the required maintenance has been performed and, has been properly installed and operated, the product will be either repaired or replaced, at HFC's sole determination, free of additional charge, and the goods will be returned, transportation paid by HFC, using a transportation method selected by HFC.

Prior to returning the product to HFC, Purchaser must obtain a Returned Material Authorization (RMA) Number from HFC's Customer Service Department within 30 days after discovery of a purported breach of warranty, but not later than the warranty period; otherwise, such claims shall be deemed waived. See the Return Requests/inquiries Section of this manual.

If HFC's inspection reveals the Hoffer product to be free of defects in material and workmanship or such inspection reveals the goods were improperly used, improperly installed, and/or improperly selected for service intended, HFC will notify the purchaser in writing and will deliver the goods back to Purchaser upon receipt of Purchaser's written instructions and agreement to pay the cost of transportation. If Purchaser does not respond within thirty (30) days after notice from HFC, the goods will be disposed of in HFC's discretion.

HFC does not warrant the product to meet the requirements of any safety code of any state, municipality, or other jurisdiction, and Purchaser assumes all risk and liability whatsoever resulting from the use thereof, whether used singlely or in combination with other machines or apparatus.

This warranty shall not apply to any HFC product or parts thereof, which have been repaired outside HFC's factory or altered in any way, or have been subject to misuse, negligence, or accident, or have not been operated in accordance with HFC's printed instructions or have been operated under conditions more severe than, or otherwise exceeding, those set forth in the specifications.

FOR <u>NON-WARRANTY</u> REPAIRS OR <u>CALIBRATIONS</u>, consult HOFFER FLOW CONTROLS for current repair/calibration charges. Have the following information available BEFORE contacting HOFFER FLOW CONTROLS:

- 1. P.O. number to cover the COST of the repair/calibration,
- 2. Model and serial number of the product, and
- 3. Repair instructions and/or specific problems relative to the product.

TABLE OF CONTENTS

| WARRANTY PERIOD LISTED BY PRODUCT | 7 |
|-----------------------------------------------------------------------|----|
| INTRODUCTION | 8 |
| PRINCIPLE OF TURBINE FLOWMETER OPERATION | 8 |
| MATERIAL SELECTION AND CONSTRUCTION | 8 |
| BEARING SELECTION | 9 |
| FLOWMETER PICKUP SELECTION | 9 |
| FLOWMETER CALIBRATIONS | 11 |
| GENERAL INSTALLATION PROCEDURE | 12 |
| STRAINERS/FILTERS | 14 |
| FLOW STRAIGHTENERS and INSTALLATION KITS | 15 |
| SIGNAL CABLES | 16 |
| SIGNAL CONDITIONERS/CONVERTERS | 16 |
| PREVENTIVE MAINTENANCE AND TROUBLE SHOOTING | 17 |
| PICKUP COIL TESTINGCLEANING AND HANDLING OF METER WHEN OUT OF SERVICE | 17 |
| BEARING REPLACEMENT | |
| BEARING REPLACEMENT for THREADED SHAFTS | 13 |
| BEARING REPLACEMENT for NON-THREADED SHAFTS | 14 |
| BEARING REPLACEMENT for WING NUT (WECO) METERS | 16 |
| WEAR LIMITS for WING NUT (WECO) METERS | 18 |
| HO SERIES CALIBRATED SPARE OR REPLACEMENT | 19 |
| INTERNAL KITS | 19 |
| SPARE OR REPLACEMENT PICKUP COILS | 19 |
| PART NO. DESCRIPTION OF SERVICE TEMP. RATING | 19 |
| REDI-PULSE PICKUP COILS: | 19 |
| RECOMMENDED SPARE AND REPLACEMENT PARTS | 20 |
| STORAGE OF THE TURBINE FLOWMETER | 21 |
| ADDENDUM: INSTALLATION OF CSA EXPLOSION PROOF CERTIFIED PRODUCT | 22 |
| APPENDIX A – HAZARD ANALYSIS | 24 |
| APPENDIX B – PRESSURE EQUIPMENT DIRECTIVE (PED) | 27 |
| APPENDIX C – DRAWINGS | 29 |
| HP_228 | |

WARRANTY PERIOD LISTED BY PRODUCT

5 Year Limited Warranty

API Precision HO Series – Excluding pickup coils Liquid Precision HO Series – Excluding pickup coils Gas Precision HO Series – Excluding pickup coils CT Custody Transfer Series – Excluding pickup coils

| 1 Year Limited Warranty | | | | |
|-------------------------------------------------|-------|--------------|--|--|
| Type Series Service | | | | |
| Sanitary | НО | Liquid | | |
| Star/Industrial | НО | Liquid | | |
| Teflon | НО | Liquid | | |
| Mini-Flowmeter | MF | Liquid & Gas | | |
| Insertion | HP | Liquid & Gas | | |
| Wing Nut* | НО | Liquid | | |
| Grooved | НО | Liquid | | |
| PD Meters | HOG | Liquid | | |
| OEM | Lo-Co | Liquid | | |
| Pickup Coils | All | | | |
| Signal Conditioners, | All | | | |
| Converters & Electronic | | | | |
| Accessories | | | | |
| Flowstar & Nova-Flow | All | | | |
| Series Flow Computers | | | | |
| ACE & ACE II | All | | | |
| Digital & Analog Totalizers/Rate Indicators. | | | | |
| Electronic Spares/Cables & Replacement parts. | | | | |
| All outside purchased items such as: Valves, | | | | |
| Strainers, Pressure & Temperature Transmitters. | | | | |

*Note: Turbine flowmeters are ideally suited for service in clean liquid and gas service.

Certain Hoffer turbine flowmeter series may be enhanced for use in slurry type flow applications. The flowmeter internals will eventually wear when the turbine flowmeter is installed in a "dirty" type of flow application. The rate of wear is a function of flow velocity, the type of slurry service, and the percentage of particulate to liquid. HFC is unable to predict the life of the flowmeter internals for slurry applications. Our standard product warranty does not apply for flowmeters that will be used in slurry type applications.

Page 1

INTRODUCTION

We are proud that you have selected a Hoffer Turbine Flowmeter, the finest precision turbine flow transducer on the market.

The Hoffer Turbine Flowmeter has been designed, constructed, and selected for your application with care by a qualified staff of professional engineers, technicians, and sales personnel.

We welcome you to our growing family of satisfied customers. If you are not completely satisfied with either our product or service, we encourage you to let us know. We want to improve!

The following information is provided for the proper installation and maintenance of your instrument.

PRINCIPLE OF TURBINE FLOWMETER OPERATION

The flowmeter is a volumetric measuring turbine type.

The flowing fluid engages the vaned rotor causing it to rotate at an angular velocity proportional to the fluid flow rate.

The angular velocity of the rotor results in the generation of an electrical signal (AC sine wave type) in the pickup. The summation of the pulsing electrical signal is related directly to total flow. The frequency of the signal relates directly to flow rate.

The vaned rotor is the only moving part of the flowmeter.

MATERIAL SELECTION AND CONSTRUCTION

Hoffer Turbine Flowmeters are available in a broad range of standard and special materials. The wide range of construction options allows for the selection of the optimum combination of useful range, corrosion resistance, and operating life for a particular application. A low mass rotor design allows for rapid dynamic response which permits the turbine flowmeter to be used in pulsating flow applications. The deflector cones eliminate downstream thrust on the rotor and allows for hydrodynamic positioning of the rotor between deflector cones.

The hydrodynamic positioning of the low mass rotor provides wider rangeability and longer bearing life than that of conventional turbine flowmeters. Integral flow straightening tubes minimize the effects of upstream flow turbulence.

The housing is made of nonmagnetic materials. The rotor is made of magnetic or magnetized material. Bearings are chosen based on service fluid, cost, and accuracy considerations.

Standard materials of construction are 316 stainless steel for the flowmeter body and rotor supports. The rotor materials of construction include 17.4 pH SS, NICKEL 200 and 430 SS. Many special materials are available for meter construction, some of which include teflon, 4130 steel, monel, other grades of stainless steel, hastalloy, titanium, tantalum, and numerous other exotic materials.

Selection of the materials of construction is usually dictated by requirements of media compatibility, availability, and cost considerations.

The materials supplied in your flowmeter have been selected for the best service of your application.

BEARING SELECTION

Numerous bearing types are available including ball bearings and sleeve type construction in tungsten carbide, Teflon, and carbon graphite composite.

When selecting among several chemically compatible bearings, the ball bearing design offers the highest accuracy and generally will have the widest usable range. It remains the bearing of choice in many fluids and is required for gas flowmeters.

Tungsten carbide bearings offer the most durable bearing material for service fluids in which it is compatible. These represent the standard bearing type for many industrial service environments.

Teflon and carbon graphite composite bearings offer properties which are nearly chemically inert to many corrosive fluids and are utilized primarily for this reason.

In turbine flowmeters, the flowing fluid provides the bearing lubrication in most applications. It may be observed that fluids which offer a high natural lubricity tend to prolong the life of the flowmeter. Many bearing types offer advantages in that they provide self-lubrications as well as providing a wear resistant surface. Among these bearing materials are carbon graphite composites, teflon, and some ball bearing designs.

Bearing life has been found to be approximately inversely proportional to the square of the bearing speed. To prolong the life of the flowmeter, it is therefore advantageous to operate the flowmeter at rates less than the maximum flowrate. For example, if the flowmeter is operated at 1/3 of the maximum flowrate, it will wear at approximately 1/10 the rate.

The bearings in your flowmeter have been selected by our staff based on what we have found to be the best choice for your application.

FLOWMETER PICKUP SELECTION

The flowmeter pickup senses the motion of the rotor and converts it to a pulsing electrical signal which is of a discrete, digital nature.

Hoffer Flow Controls offers several pickup types suited for different applications. The advantages of each are listed.

HIGH OUTPUT MAGNETIC PICKUP - TYPICAL RANGE 10:1

The standard pickup for turbine flowmeters larger than 1 inch produces a high level sinusoidal output. To produce this, the pickup generates a relatively high magnetic field. The signal may be transmitted up to 200 feet without amplification. A flow range of 10:1 or better is common with this pickup type.

LOW DRAG MAGNETIC PICKUP - TYPICAL RANGE 25:1

Low drag magnetic pickups may be used to obtain a flowmeter range of 25:1 or better. They offer a significant reduction in drag effects with lower output levels and may require pre-amplification prior to transmission. Low drag magnetic pickups are used extensively in meter sizes below 1 inch.

MAGNETIC PICKUP OUTPUT SIGNAL CHARACTERISTICS

The output signal voltage of the magnetic coil is approximately sinusoidal. The frequency range of the pulsing signal varies from meter size to meter size. However, standard ranges allow for maximum output frequencies at the nominal linear flow of 250, 500, 750, 1000, 1500, 2000, and 2500 Hz.

The amplitude of the output signal is a function of flowrate. The voltage at the minimum linear flow is greater than 30 millivolts peak to peak when measured into a 10.000 ohm load.

On larger size flowmeters the output level may exceed several volts peak to peak. The DC output resistance of the magnetic pickup coil is generally less than 2,000 ohms. Detailed impedance characteristics are available on request.

MODULATED CARRIER PICKUP (MCP) - TYPICAL RANGE 100:1

The Hoffer MCP pickup is an active coil which eliminates pickup drag and requires a Modulated Carrier Signal Conditioner be mounted on or near (10 feet or less) the flowmeter. The MCP works on a principle where the motion of the rotor modulates a high frequency signal. The conditioner demodulates, filters, amplifies, and shapes the resulting signal prior to transmitting it as a high level signal. Use of the MCP pickup allows for wider flow ranges than can be achieved with low drag magnetic pickups. The cost compares with that of a preamplifier for a magnetic pickup. This pickup type is used extensively when a wide flow range is required or with flowmeters that are being used with a universal viscosity calibration curve (UVC). Typically, MCP coils can obtain flowmeter ranges of up to 100:1.

OUADRATURE OUTPUT OPTION

When a Hoffer Turbine Flowmeter is equipped with two pickup coils properly positioned on the flowmeter housing, it is possible to sense flow direction, flowrate and total flow as well as add/subtract options.

The pickup coils generate two output signals with a quadrature (90°) phase difference. With suitable electronic phase discriminating circuitry, it is possible to provide two separate output signals, one of which is related to flow in the forward direction only, with the second relating to flow in the reverse direction only.

Hoffer Turbine Flowmeters, unlike many other turbines, are built physically symmetrical which inherently makes bi-directional flow measurement possible with only the addition of a second pickup coil, keeping cost considerably less than other manufacturers. Other considerations which may dictate equipping two pickup coils on a single flowmeter arise from advantages in the ease of achieving parallel signal processing or increased reliability.

HAZARDOUS AND WEATHERPROOF ENVIRONMENTAL COIL ENCLOSURES

The explosion proof requirements of UL Class I, Group C and D, Class II, and NEMA 4X are routinely provided for by enclosing the pickup coil in a suitable housing. Signal conditioners and converters can readily be mounted on the flowmeter. Hoffer Turbine Flowmeters are inherently safer since they require no through holes eliminating the possibility of a leak.

FLOWMETER CALIBRATIONS

The standard calibration provided with most Hoffer Turbine Flowmeters consists of a 10-point water calibration over the linear flow range of the meter. A number of optional flowmeter calibrations may also be requested.

A 10-point water calibration over the extended range of the meter may be requested at no additional charge. Additional calibration points may be requested within the linear range or in the extended range at additional cost.

Fluids other than water are used to simulate viscosity conditions from 2 to 300 centistokes. Where it is necessary to document flowmeter performance for viscous service, the flowmeter calibration simulates the viscosity, as well as, the flow rate anticipated in actual service.

Universal Viscosity Calibration (UVC) curves may be documented for each Hoffer Turbine Flowmeter where this information is required to achieve maximum flowmeter accuracy in medium to high viscosity service.

In general, any flowmeter size may be supplied with a UVC. However, since smaller meter sizes (under one inch) display the largest sensitivity of calibration factor to viscosity, it is this size range which is the most likely to be considered for a UVC.

The UVC may be utilized to determine the K-Factor either graphically, or in the case of an intelligent instrument, algorithmically, for a measured set of flowing conditions.

Hoffer offers a standard viscosity calibration which consists of ten repeated points for each viscosity required. A typical UVC curve requires three sets of ten points plotted as a continuous curve. In addition, Hoffer offers a ten point single viscosity (up to 300 centistokes) calibration at a nominal additional fee.

GENERAL INSTALLATION PROCEDURE

Upon receipt of the turbine flowmeter a visual inspection should be performed checking for any indications of damage which may have occurred during shipment. Inspect all packing material carefully to prevent the loss of meter parts or auxiliary components which may have been packed with the shipment. Refer to the packing list/invoice for a detailed list of items included in the shipment.

The meter housing is marked by a flow direction arrow and the inlet is marked 'IN' and the outlet is marked 'OUT'. The meter must be installed in the piping in the correct orientation to ensure the most accurate and reliable operation. Care should be taken in the proper selection of the mating fittings. Size, type of material, and pressure rating should be the same as the flowmeter supplied. The correct gaskets and bolts should be utilized.

The flowmeter may be installed horizontally or vertically for gas service without affecting the meter calibration, however, in liquid applications the meter must be installed horizontally for proper operation. When it is expected that flow will be intermittent, the meter should not be mounted at a low point in the piping system. Solids which settle or congeal in the meter may affect meter performance.

In order to achieve optimum electrical signal output from the flowmeter, due consideration must be given to its isolation from ambient electrical interference such as nearby motors, transformers, and solenoids.

GENERAL PIPING CONSIDERATION

As stated in the Principle of Flowmeter Operation, the fluid moving through the flowmeter engages the vaned rotor. Swirl present in the fluid ahead of the meter can change the effective angle of engagement and, therefore, cause a deviation from the supplied calibration (performed under controlled flow conditions). Turbine meters are constructed with flow straighteners to minimize the affects of fluid swirl and non-uniform velocity profiles are adequate for most installations. However, it is good practice to maintain a minimum straight run of pipe approximately 10 pipe diameters ahead of the inlet and 5 pipe diameters following the outlet. Proper installation of the flowmeter minimizes the negative effects of fluid swirl.

Page 6

A typical flowmeter installation is shown below:




Figure 1: Typical Flowmeter Installation

Blocking and Bypass valves should be installed if it is necessary to do preventive maintenance on the flowmeter without shutting down the flow system. The Bypass valve can be opened before the Blocking valves allowing the flow to continue while removing the turbine flowmeter for service.

IMPORTANT: All flow lines should be purged prior to installing the meter. To prevent possible damage to the meter, install the meter ONLY in flow lines that are clean and free of debris.

Upon initial start-up of the system a spool piece should be installed in place of the flowmeter so that purging of the system can be performed to remove all particle debris which could cause damage to the meter internals. In applications where meter flushing is required after meter service, care should be taken as to not over-speed the meter, as severe meter damage may occur.

CAUTION: Avoid over-spinning the meter. Over-spinning the meter may cause damage to the meter internals and lead to needless meter failure.

To maintain an accurate flow measurement it is necessary to maintain a downstream pressure sufficient to prevent flashing/cavitation. Flashing of the liquid will result in an indication of flow significantly higher than the actual flow. In order to eliminate this condition adequate downstream pressure must be maintained. The minimum required downstream pressure may be calculated using the following equation:

 $MinimumPressure = (2 \times PressureDrop) + (1.25 \times VaporPressure)$

Downstream pressure may be maintained by a downstream valve that provides the necessary downstream pressure to prevent flashing/cavitation in the metering run.

STRAINERS/FILTERS

Turbine flowmeters are designed for use in a clean fluid service. However, the service fluid may carry some particulate material which would need to be removed before reaching the flowmeter. Under these conditions a strainer/filter may be required to reduce the potential hazard of fouling or damage that may be caused by foreign matter. Strainer/filters are recommended to be used with the Hoffer Mini-Flow Series meters.

| METER SIZE | MESH SIZE | PARTICLE SIZE (Maximum) |
|----------------------------------------------------------------|-----------|----------------------------|
| MF Series | 100 | .0055 |
| ¹ / ₄ " to ¹ / ₂ " | 100 | .0055 |
| $^{5}/_{8}$ " to $1^{1}/_{4}$ " | 70 | .008 |
| 1½" to 3" | 40 | .015 |
| 4" to 12" | 24 | .028 |

If a strainer/filter is required in the system, it should be located upstream of the flowmeter taking care that the proper minimum distance is kept between the strainer and flowmeter.

FLOW STRAIGHTENERS and INSTALLATION KITS

FLOW STRAIGHTENING

Proper application of the Hoffer Turbine Flowmeter requires a suitable piping section to achieve optimum accuracy. While an inlet straight pipe run of 10 pipe diameters and an outlet straight pipe run of 5 pipe diameters provide the necessary flow conditioning in general, some applications require an upstream flow straightener. This consists of a section of piping that contains a suitably dimensioned and positioned thin walled tube cluster to eliminate fluid swirl.




Figure 2 Typical Flow Straightener

A typical application requiring a flow straightener would be custody transfer.

Flanged flow straightening sections are available from $\frac{1}{2}$ " to 12" line sizes with mating fittings in pressure ratings from 150# to 2500# ratings. Beveled type end fittings for welding are also available.

MS INSTALLATION KITS

Installation kits for the MS end fittings consist of two lengths of stainless steel tubing cut to a length appropriate for the upstream and downstream straight pipe run and flared at one end. Mating sleeves and nuts are included. The kits may be conveniently butt welded into the user's piping. Alternately the kits may be provided with NPT or flanged connections to facilitate installation of smaller flowmeters into larger existing lines. This adapted form of the installation kit is recommended for use with the Hoffer Mini Flowmeters since only MS end fittings are offered in the Mini Flow Series.

Flow straightening sections may be provided within the installation kit.

MS installation kits are available in turbine sizes from \(\frac{1}{4} \)" to 2".

SIGNAL CABLES

Two conductor shielded cabling recommended for the Hoffer Turbine Flowmeter is generally available in most industrial settings. However, Hoffer stocks cabling for user convenience. Cabling is available cut to length with dressed end connections. Recommended cable is Beldon 8422 or equal.

SIGNAL CONDITIONERS/CONVERTERS

Consideration should be given to properly interface the turbine flowmeter output to the host electronics. If the system is installed in an electrically noisy area or if the distance from the turbine flowmeter to the host electronics exceeds 500 feet a signal conditioner may be necessary.

Hoffer Signal Conditioners for the turbine flowmeter provide amplification, filtering, and wave shaping of the low level flowmeter pickup signal and generate a high level pulse output signal suitable for transmission to a remote host system through a noisy environment.

Several output forms (i.e., TTL/CMOS, open collector, etc.) are available to suit various interface requirements. The conditioned pulse output signal may be transmitted several thousand feet.

| Note: | The standard (1) year warranty applies to all coils, signal |
|-------|-------------------------------------------------------------|
| | conditioners/converters and Hoffer electronics. |

PREVENTIVE MAINTENANCE AND TROUBLE SHOOTING PICKUP COIL TESTING

Testing the MAG and MCP (RF) coils consists of measuring the resistance with an ohmmeter.

Measure the resistance between pin A and pin B. The resistance should be approximately as listed in the following table.

The resistance from any pin to the case should be greater than 1 megohm.

Table A - DC Resistance of some common coils*

| COIL | DC RESISTANCE |
|-----------|-----------------|
| COIL | (Ohms) |
| MC2PAHT | $15.0 \pm 10\%$ |
| MCP | $2.5 \pm 10\%$ |
| MCP3A | $11.5 \pm 10\%$ |
| PC13-110G | $1800 \pm 10\%$ |
| PC13-70G | $1800 \pm 10\%$ |
| PC13-74G | $1800 \pm 10\%$ |
| PC13-74S | $1850 \pm 15\%$ |
| PC24-45G | $1350 \pm 10\%$ |
| PC24-45S | $1850 \pm 15\%$ |
| PC28-13G | 120 ±20% |
| PC28-14G | 180 ±20% |
| | |

If either resistance measurement fails, replace the pickup coil. Firmly seat the new coil in the flowmeter.

CLEANING AND HANDLING OF METER WHEN OUT OF SERVICE

When the flow meter has been installed in a line that will be temporarily out of service and has either been partially or fully drained, bearing corrosion may occur. The rate of corrosion depends on the corrosiveness of the fluid being metered, bearing type and the duration that the flowmeter will be out of service. It is recommended that the flowmeter be removed, cleaned, and stored during the out of service period. This recommendation also applies to any startup testing performed on a liquid meter using municipal water.

Recommendations for each type of bearing are as follows:

^{*} For specific coils not listed contact the HFC Customer Service Department for the approximate resistance readings.

Ceramic Hybrid Ball Bearing: The meter should be flushed with isopropyl alcohol or similar cleaning solution and allowed to air dry.

Tungsten Carbide Bushing: The meter should be disassembled, internal components cleaned with isopropyl alcohol or similar cleaning solution and dried.

Hard Carbon Composite Bushing: The meter should be flushed with clean filtered water and allowed to air dry.

Note: Compressed air (shop air) should never be used to dry meter internals.

BEARING REPLACEMENT

HP-228

The type of bearings installed in the flowmeter have been selected to operate in the type of service being metered.

It is recommended that the bearings be checked periodically for wear. The type of fluid being measured, as well as temperature and cleanliness of the service, have a direct relationship on the life expectancy of the bearings. Therefore, it is best to contact the engineering department or the HFC Customer Service department for the proper preventive maintenance interval.

It is recommended that the bearings be replaced if any signs of wear are apparent. An unexplained shift in the output accuracy could be a sign of worn bearings.

CAUTION: If bearings are allowed to operate without replacement at the recommended interval, the accuracy of the device may drift from the original calibration and if left long enough severe damage to the rotor and/or internals may occur.

Ball bearings can be changed in the field. Sleeve type bearings cannot be changed in the field. If no down time can be tolerated, a spare rotor with sleeve bearing or complete set of spare internals should be stocked.




Figure 1 Exploded View - Flowmeter Internals
Turbine Flowmeter Manual

Page 12

BEARING REPLACEMENT FOR THREADED SHAFTS

- Remove the meter to a clean stable work surface.
- 2. Using two wrenches, remove one lock nut from the shaft.
- 3. Remove hanger, shaft, cones, rotor and bearings from the housing.
- 4. Place assembly on a clean surface; carefully remove a cone, two bearings and the rotor.
- 5. Remove the other hanger in a similar manner.
- 6. Examine the shaft and cones for scoring. If scoring is present, replacement is necessary.
- 7. Obtain new bearings of the same type from stock or the manufacturer. Discard old bearings.
- 8. Reassemble one hanger in the housing with the shaft, a cone, and lock nut.
- Place the bearings into the rotor. Guide the bearings and rotor onto the shaft making sure to reassemble with the "IN" side of rotor facing the "IN" side of the housing.
- 10. Place the remaining cone on the shaft. Gently "rattle" the flowmeter to seat the internals on the shaft.
- 11. When properly seated, gently push the hanger onto the shaft. Be sure to properly align the hanger on the shaft. The hangers seat against a shoulder machined into the housing.
- 12. For meter sizes 1/4" thru 1", gently tighten the nuts and washers until they make contact with the spring clip hanger. "Two Finger" tight on a "Spin-Tite" is more than adequate. Verify that the cones do not rotate freely on the shaft. Do not over tighten the shaft nuts; damage to the threads will occur.
- 13. For meter sizes 11/4" and larger, gently tighten the self-locking nuts until they make contact with the spring clip hanger. Verify that the cones do not rotate freely on the shaft. Do not over tighten the shaft nuts; damage to the threads will occur.
- 14. Holding the meter horizontally, gently blow into it (DO NOT use compressed air). The rotor should turn freely. With a magnetic coil the rotor should gradually slow down and then "quiver" to a stop with one of its blades aligning with the pickup coil. With a MCP (RF) coil the rotor should "coast" smoothly to a stop.
- 15. Clean the flowmeter assembly with ISOPROPYL ALCOHOL or an alternately approved cleaning solution.

The flowmeter is ready for service. When installing the flowmeter be sure to orientate the "in" and "out" correctly.


BEARING REPLACEMENT FOR NON-THREADED SHAFTS

- 1. Remove meter to a clean stable work surface.
- 2. Insert the hanger tool (3P-Tool HFC Stock # 300-8113) into the hanger/flow straightener assembly.
- 3. Turn the 3P-Tool until the hanger tubes are aligned with the scallops in the meter housing.
- 4. Holding the meter in the vertical direction slowly remove the tool. The hanger, shaft, cones, rotor, and bearings should come out with the tool. Should any of the components hang-up inside the meter housing care should be taken in their removal.
- 5. Remove the remaining hanger in a similar manner.
- Examine the shaft and cones for scoring. If scoring is present, replacement is necessary.
- Obtain new bearings of the same type from stock or the manufacturer. Discard old bearings.
- 8. Insert the shaft with cone into the hanger and assemble the remaining internal parts onto the shaft.
- 9. Place the hanger assembly with the internals on the 3P-Tool.
- 10. Hold the housing in the vertical position and align the hanger assembly with the scallops in the meter housing.
- 11. Gently slide the hanger and rotor assembly into the housing with the "IN" on the rotor oriented in the same direction as the "IN" on the housing.
- 12. When the hanger assembly is fully inserted into the meter housing, twist the 3P-Tool to secure the hanger in the 'locked' position.
- 13. Align the second hanger with the scallops on the housing and with the shaft.

Caution: It is very important that the shaft is properly inserted into the second hanger. Failure to do so will result in damage to the rotor, shaft, and/or bearings.

- 14. With the hanger properly positioned in the housing, secure it in place by inserting the 3P-Tool and twisting it to the 'locked' position.
- 15. Using the 3P-Tool align the tubes of the two hangers.
- 16. Holding the meter horizontally, gently blow into it (DO NOT use compressed air). The rotor should turn freely. With a magnetic coil the rotor should gradually slow down and then "quiver" to a stop with one of its blades aligning with the pickup coil. With a MCP (RF) coil the rotor should "coast" smoothly to a stop.
- 17. Clean the flowmeter assembly with ISOPROPYL ALCOHOL or an alternately approved cleaning solution.

The flowmeter is ready for service. When installing the flowmeter be sure to orientate the in and out correctly.




BEARING REPLACEMENT FOR WING NUT (WECO) METERS

For 1" and 11/2" meters (HO2x1 and HO2x1/1/2) follow bearing replacement procedure for threaded shafts on page 12.


For 2" and 3" meters (HO2x2 and HO3x3) a spiral retaining ring on the downstream (OUT) side of the meter must be removed first before removal of internals.

- 1. Using a long pic tool, locate the end of the spiral ring and pry it toward the center of the housing. Using a tool with a hooked end, pull the retainer out of the housing.
- 2. Follow bearing replacement procedure for threaded shafts on page 12.
- 3. After internals have been installed and checked, install new retainer ring.



Wing Nut Meter with Ball Bearings (BB)

| F | PARTS LIST | | |
|---|----------------|--|--|
| 1 | HOUSING | | |
| 2 | LOCK NUT | | |
| 3 | HANGER ASSY | | |
| 4 | CONE | | |
| 5 | ROTOR | | |
| 6 | SHAFT | | |
| 7 | PICKUP COIL | | |
| 8 | RETAINING RING | | |
| 9 | BALL BEARINGS | | |




Wing Nut Meter with Tungsten Composite Sleeve Bearing (TC)

| PARTS LIST | | |
|------------|----------------|--|
| 1 | HOUSING | |
| 2 | LOCK NUT | |
| 3 | HANGER ASSY | |
| 4 | CONE | |
| 5 | ROTOR | |
| 6 | SHAFT | |
| 7 | JOURNAL | |
| 8 | THRUST WASHER | |
| 9 | RETAINING RING | |

WEAR LIMITS FOR WING NUT (WECO) METERS

The Wing Nut style liquid and gas turbine flow meters are often used in abrasive fluids being pumped at high velocity. Under these conditions the meter body is subjected to accelerated wear and it should be inspected periodically. Hoffer specification allows an increased inside bore diameter up to 0.020". Refer to the table below for maximum allowable bore diameters.

Note the limitation on wear is not a pressure related limit, but is an assembly and meter performance related limit. If bore diameter increases by 0.020" there is no significant effect on pressure rating. However, internal hangers may start spinning causing further damage to the meter and meter K-factor may shift significantly causing a measuring error.



Refer to Hoffer Technical Note TN-17 for a full discussion on Wing Nut meter wear limits.

Maximum Allowable Bore Dimension:

| Meter size | A max | B max |
|------------|--------|--------|
| HO2X1 | 0.921" | 0.897" |
| HO2X11/2 | 1.392" | 1.334" |
| HO2X2 | 1.846" | 1.773" |
| HO3X3 | 2.662" | 2.601" |

HO SERIES CALIBRATED SPARE OR REPLACEMENT INTERNAL KITS

Flowmeter Size



Minimum Flow Range

14 · El D

Maximum Flow Range

Bearing Type

CB - Ceramic Hybrid self-lubricating ball bearings.

MODEL

- Internals

T - Tungsten Carbide

TFE - Teflon

C - Hard Carbon Composite

SPARE OR REPLACEMENT PICKUP COILS

| PART NO. | DESCRIPTION OF SERVICE | TEMPERATURE RATING |
|---------------|--------------------------------------------------|---------------------------|
| MC3PAE | RF Coil 1/2" MNPT & 3" Leads | -50° to +400°F |
| MC3PA | RF Coil All HO Series | -50° to +400°F |
| PC13-110G | Cryogenic HO1 & Up | -450° to +450°F |
| PC13-74G | WECO HO 2X2 & HO 3X3 Liquid & Navy | -450° to +450°F |
| PC13-74S | HO Series HO1 & Up & Mini-Flows | -450° to +450°F |
| PC24-45G | HO1/4 thru HO3/4 Cryogenic, Trident & SY100 | -450° to +450°F |
| PC24-45S | HO1/4 thru HO3/4 & HO1 & Larger Gas | -450° to +450°F |
| PC24-45EX | HO1/4 thru HO3/4 & HO1 & Larger Gas with ½" MNPT | -450° to +450°F |
| | & 3" Leads | |
| | Temp High Drag | -450° to +850°F |
| | ctance Center Mag for All Teflon | -35° to +120°F |
| | rogen Vacuum Jacket | -450° to +450°F |
| | Temp Low Drag | -450° to +850°F |
| | ctance Teflon Series with ½" MNPT & 3" Leads | -35° to +120°F |
| | Temp RF with 3' Leads | -50° to +450°F |
| | Temp 2 Pin RF | -50° to +330°F |
| PC13-108G | Cryogenic 1" & Larger | -450° to +450°F |
| PC24-113G | | -450° to +450°F |
| PC13-74EX | Hi Drag with ½" MNPT & 3" Leads | -450° to +450°F |
| | ogenic 1" & Larger | -450° to +450°F |
| | CO's All Sizes Requiring RF | -325° to +325°F |
| | nsic Mag Hi Drag 1" & Up & Mini-Flow Use | -97° to +207°F |
| PC24-123G | WECO HO2X2 & HO3X3 Gas | -450° to +450°F |
| | nsic Mag Low Drag ¾" & Smaller Use | -97º to +207ºF |
| | nsic Reluctance For All Teflon Use | -35° to +120°F |
| | emp/Hi Drag For WECO HO2X11/2 & HO2X1 | -450° to +850°F |
| | ctance Teflon Hi Output | -35° to +120°F |
| | Effect Coil For HOG | -40° to +302°F |
| M-L3/8X1.52 | Lo-Co Coil | -50° to +250°F |
| REDI-PULSE PI | ICKUP COILS: | |
| RPMxxx Redi | -Pulse Mag Coil | -40° to +185°F |
| RPRxxx | Redi-Pulse RF Coil | -40° to +185°F |
| DMXxxx | Redi-Pulse Intrinsically Safe Mag Coil | -40° to +185°F |
| DRXxxx | Redi-Pulse Intrinsically Safe RF Coil | -40° to +185°F |

NOTE: For the complete part number of the Redi-Pulse Pickup Coils or Intrinsically Safe Redi-Pulse Pickup Coils, Consult Factory.

RECOMMENDED SPARE AND REPLACEMENT PARTS

To assure maximum operating efficiency and minimum down time it is recommended that the following parts be stocked at all times.

| <u>Part*</u> | <u>Nomenclature</u> | Qty. |
|--------------------------------------|--------------------------------------------------------------------------------------------------|---------|
| Pickup Coil | Pickup Coil | 1 |
| Bearings | Ball Bearing type only | 1 (set) |
| Rotor Assembly | Rotor with sleeve bearing | 1 |
| Complete Calibrated Internals Kit | Assembled & calibrated meter internals consisting of rotor, shaft, cones, bearings, and hangers. | 1 |

NOTE: Recommended spare parts lists should not be construed as an indication of possible failure, but reflect material available only from the manufacturer or his authorized representative.

Quantity of recommended spares is based upon a single unit at any given location and provisioning may be adjusted accordingly in the event that multiple units comprise a system.

HP-228

^{*} Contact the HFC Customer Service Department with the equipment model and serial number for the part numbers and current pricing for recommend spare parts.

STORAGE OF THE TURBINE FLOWMETER

The internal components of the turbine flowmeter are precision components which must be handled with care, and therefore, only qualified personnel should service the flowmeter.

Industrial Applications

When a turbine meter is removed from the process fluid to be placed in storage, the following preventative actions should be taken in order to prevent bearing failure:

For corrosive or non-lubricating fluids (excluding cryogenic and gas meters).

- 1. Clean all components with alcohol and allow to dry completely.
- 2. Coat all parts with machine oil.

For lubricating fluids.

1. Coat all parts with machine oil.

No abrasive material, such as emery paper or crocus cloth, should be used to clean any of the internal parts of the flowmeter.

After the flowmeter is properly cleaned and coated with oil, the end fittings should be covered with end caps so that no foreign material can enter the meter while in storage.

Cryogenic Application

In cryogenic applications, if the turbine flowmeter is removed from service and placed in storage, the meter must first be disassembled in a clean area. The area should be free from dust, oil, moisture, organic/inorganic particles, and any other pollutants which could contaminate the flowmeter components. Follow the procedures for bearing replacement as previously discussed.

Reassemble the flowmeter (after installing new bearings and replacing any worn parts). Next, the flowmeter should be immersed and thoroughly washed in an approved solvent. Take care to remove any oils or other contaminants present. At the conclusion of the solvent wash, allow the flowmeter to air dry.

The cleaned flowmeter should be placed in a plastic bag and electrically sealed for storage. The flowmeter is then tagged as "Cleaned for Cryogenic Service".

Sanitary Applications

When a sanitary turbine flowmeter is removed from service and placed in storage, the meter must first be cleaned by the recommended 3-A cleaning specifications. The flowmeter should then be allowed to thoroughly dry before storing. Once the meter is thoroughly dry, cap the end fittings so that no particles can enter the meter. Place the meter in a sealed plastic bag for storage.

When placing the sanitary meter back into service, remove the meter from the sealed bag and remove the protective caps. Clean the flowmeter as required by 3-A cleaning specifications before placing meter in service.

ADDENDUM

Installation of CSA Explosion-Proof Certified Product

Several Turbine flow meter product series have been certified by CSA for use in hazardous locations. These product lines are certified for use in the following hazardous locations:

Class I, Div 1, Groups ABCD; Class I, Div 2, Groups ABCD; Class II, Div 1, Groups EFG

Canada: Class I, Zone 1 and 2, Ex d IIC USA: Class I, Zone 1 and 2, AEx d IIC

Certified Turbine Flow Meters model series HO consisting of the following product lines:

HO Custody Transfer Meters, model series HO-API-x in meter sizes 1", $1\frac{1}{2}$ ", 2", $2\frac{1}{2}$ ", 3" & 4" and HO-CT-100C-x in meter sizes 4", 6", 8", 10" & 12" in Stainless Steel or Carbon Steel meter bodies. Rated: -80°C to +180°C; Single Seal.

HO Grooved Meters, model series HO-GF-x in meter sizes 1", 1 ½", 2", 2 ½", 3", 4", 6", 8", 10" & 12" in Stainless Steel meter bodies.

Rated: -80°C to +180°C; Single Seal.

HO Gas Service Meters, model HO-G-x in meter sizes ¼", ¾", ¾", ¾", 1", 1 ¼", 1 ½", 2", 2 ½", 3", 4", 5", 6", 8", 10" & 12" in Stainless Steel or Carbon Steel meter bodies. Rated: -80°C to +180°C; Single Seal.

HO Liquid Service Meters, model HO-L-110I-x in meter sizes ¼", ¾", ½", ½", ½", ¾", 1", 1 ½", 1 ½", 2", 2 ½", 3", 4", 5", 6", 8", 10" & 12" in Stainless Steel or Carbon Steel meter bodies. Rated: -80°C to +180°C; Single Seal.

HO Premium Gas Meters, model HO-PG-100B-x in meter sizes ½", ½", ½", ½", ½", 1", 1 ½", 1 ½", 2", 2 ½", 3", 4", 5", 6", 8", 10" & 12" in Stainless Steel or Carbon Steel meter bodies. Rated: -80°C to +180°C; Single Seal.

HO Industrial Star Meters, model HO-STAR-105F-x in meter sizes $\frac{1}{4}$ ", $\frac{1}{2}$ ", $\frac{3}{4}$ ", 1", 1 $\frac{1}{4}$ ", 1 $\frac{1}{2}$ ", 2", 2 $\frac{1}{2}$ " & 3" in Stainless Steel meter bodies. Rated: -80°C to +180°C; Single Seal.

HO Wafer Gas Service Meters, model HO-SWG-100E-x in meter sizes \%", \%", 1", 1 \\\d'', 1 \\\d'', 2", 2 \\\d'' \& 3" in Stainless Steel meter bodies. Rated: -80°C to +180°C; Single Seal.

HO Wafer Liquid Service Meters, model HO-SWL-100D-x in meter sizes $\frac{5}{8}$ ", $\frac{3}{4}$ ", $\frac{1}{1}$ ", $\frac{1}{4}$ ", $\frac{1}{2}$ ", $\frac{2}{1}$ ", $\frac{2}{1}$ ", $\frac{2}{1}$ ", $\frac{4}{1}$ ", $\frac{5}{1}$ ", $\frac{6}{1}$ " & 8" in Stainless Steel meter bodies. Rated: -80°C to +180°C; Single Seal.

All of the above models may be optionally equipped with a "Limatherm" electrical enclosure, model XD-AD.

Notes:

- 1. The "x" represents numerous configuration options relating to rotor bearing size, pickup coils, end fittings; etc., which do not affect the electrical and mechanical safety rating of the product.
- 2. Meters can be equipment with 1 or 2 pickup coils.

Installation Instructions

- 1. Division 1 wiring methods must be used for Division 2 installations.
- 2. Zone 1 wiring methods must be used for Zone 2 installations.
- For Class I, Group A installations using the optional "Limatherm" model XD-AD a conduit seal is required within 18" of the enclosure.

APPENDIX A

Hazard Analysis for Flow Meters and Installation Kits

Hoffer flow meters and installation kits are manufactured using PED compliant materials (if required) and are designed to operate under the specified applications and the temperature and pressure conditions.

Hazard Identification

The following hazards associated with operating Hoffer flow meters has been identified.

| Type of Hazard | Hazard Classification For Applications With Dangerous Fluids (Group 1) | Hazard Classification For Applications With Non-Dangerous Fluids (Group 2) |
|---------------------|---------------------------------------------------------------------------------|-------------------------------------------------------------------------------------|
| Pipe/Meter Bursting | Dangerous Risk | Dangerous Risk |
| Flange Leaking | Dangerous Risk | Residual Risk |
| Skalds Risk | Residual Risk | Residual Risk |

Risk Evaluation

Exceeding MAWP

The meters are design to withstand specified maximum allowable working pressure (MAWP) and temperature. The MAWP is listed on the meter drawing supplied with the meter. Under no circumstances shall fluid pressure exceed the MAWP. If the MAWP is exceeded, there is a dangerous risk of the meter or pipe bursting. In particularly, a meter could explode in pieces and flying metal debris could cause death or injury to the operator. In addition, there could be a burst of fluid contained in the meter. Fluids from Group 1 can cause fire, explosion, death or injury. Fluids from Group 2 can cause flooding, damage to the nearby equipment and short circuits in the electrical installations.

Flange Leaking

Hoffer flow meters should be installed according to the Hoffer Flow user manual. Proper fittings and washer should be used when applicable. Flanges should be tightened to the specified torque. In case of a leak from a flange or coupling, fluids from Group 1 can cause fire, explosion, death or injury. Fluids from Group 2 can cause flooding, damage to the nearby equipment and short circuits in the electrical installations.

Scalds Risk

There is a risk of skin scald in the applications where fluid operating temperatures are above 120 deg. F.

Vibration

Meters installed in vibrating pipes may develop weld defects and material cracks.

Corrosion

Meters shall be used only with corrosion compatible fluids.

Meter Internals Breakage

Meter internal parts may break when maximum allowable flow rate is exceeded.

Definition of Terms

Burst Pressure

Maximum pressure a pressure vessel can contain without rupturing.

This is a calculated pressure using the Barlow's formula

$$(P = 2*S*T/D)$$

Where P = Burst pressure

S = Minimum material tensile strength at less than 40 deg. C

T = Minimum wall thickness

D = Outside diameter of vessel

Design Pressure

Maximum pressure above which the pressure vessel may sustain structural damage or fatigue. This is a calculated pressure using the Barlow's formula (P = 2*S*T/D)

When P = Maximum design pressure

S = Minimum material yield strength at less than 40 deg. C

T = Minimum wall thickness

D = Outside diameter of the vessel

Notes:

- Design pressure can be de-rated for higher temperatures based on material yield strength at specified temperature.
- Factors such as mechanical loads neither linear nor axial have been accounted for in these calculations.

Working Pressure

Pressure of the media contained in the system during normal operating conditions.

Maximum Allowable Working Pressure

The working pressure is recommended by Hoffer Flow Controls Inc

The design pressure divided by a safety factor or a calculated pressure using Barrow's formula (P = 2*S*T/D).

When P = Maximum allowable working pressure S = Minimum material stress at max temperature according to ASME B31.3

TABLE A-1

T = Minimum wall thickness

D = Outside diameter of pressure vessel

APPENDIX B

Pressure Equipment Directive (PED)

Marking and Labeling of PED flowmeters

Manufacturer name and address
Year of manufacture
Model number
Serial number
CE mark for Category I
CE0035 mark for Category II and III
Minimum and Maximum temperature
Maximum pressure
DN number

Sample PED Markings

| SAMPLE CATEGORY I MARKINGS | SAMPLE CATEGORY II & III MARKINGS |
|-------------------------------------|-------------------------------------|
| Hoffer Flow Controls Inc. | Hoffer Flow Controls Inc. |
| Elizabeth City | Elizabeth City |
| NC USA | NC USA |
| MODEL H02X2-T-1M-F6SS-PED-CE | MODEL H02X2-T-1M-F6SS-PED-CE |
| MAX PRESS:1140 PSIG/99 BARG | MAX PRESS: 1140 PSIG/99 BARG |
| MIN./MAX TEMP: 50°F-100°F/10°C-38°C | MIN./MAX TEMP: 50'F-100'F/10'C-38'C |
| DN50 | DN50 |
| YR.MFG. 2020 | YR.MFG. 2020 |
| CE | CE0035 |

Operating Instruction

Mounting and assembling, see pages 6-9 of this manual Putting into service, see page 6 of this manual Maintenance, see pages 11-17 of this manual

APPENDIX B (cont,)

Pressure Equipment Directive (PED) Essential Safety Requirements

| No. | Hazard | Measures of Elimination/P revention | E/P | PED, Annex 1 | Measure of Protection | Residual Hazard |
|-----|--------------------------------|-----------------------------------------------|-----|--------------------------------|----------------------------------------------------------------------------------------------------------------------------|--------------------|
| 1 | Exceeding MAWP | Adequate dimensioning for MAWP | E | 2.2.1 Design Safety Factors | Operational Manual: Customer shall not exceed MAWP. Customer shall install pressure safety devices rated at 110% of MAWP | No |
| 2 | Surface Temperature | Prevent | P | | Operational Manual: Customer shall prevent operators from touching the hot surface. | Yes |
| 3 | Flonge Leaking | Prevent | P | | Operational Manual: Customer shall apply correct gaskets, bolts, and torque. | Yes |
| 4 | Vibration | Change Design to Encounter Vibration | E | 2.2.1 Design Safety Factors | Increase Safety Factors Operational Manual: Customer shall not expose product to excessive material. | No |
| 5 | Corrosion | Use Adequate Materials for Application | E | 2.2.1 Design Safety Factors | Operational Manual: Customer shall use fluids compatible with the material. | No |
| 6 | Meter Internals Breakage | Prevent | P | 2.2.1 Design Safety Factors | Operational Manual: Customer shall not exceed maximum flow rate. | Yes |

APPENDIX C

DRAWINGS

Installation Instructions For Intrinsically Safe Pickup Coils

ISM and ISMC Series

Notes:

- For CSA-NRTL Installations: Installation should be in accordance with ANSI/ISA RP12.6 "Installation of Intrinsically Safe Systems for Hazardous Locations" and the National Electric Code (ANSI/NFPA 70). For ATEX Installations: Installation should be in accordance with ATEX Directive for Installation of Intrinsically Safe systems in hazardous locations and in accordance with the relevant local Electric Codes.
- 2. For CSA Installations: Install in accordance with Canadian Electric Code Part 1. For ATEX Installations: Install in accordance with the relevant local Electric Code.
- 3. Pickup coils equipped with the "MS" type connector are only suitable for hazardous locations Class 1, Division 1, Groups A, B, C, D; Class II, Division 1 Group G, Class III, and Coal Dust. Pickup coils with an "NPT" connector or "pigtail" leads can be used in hazardous locations Class 1, Division 1, Groups A,B,C,D; Class II, Division 1, Groups E, F, G, and Class III. For ATEX installations, pickup coils are suitable for use in Ex ia IIC or IIB hazardous locations, where Exia is defined as Intrinsically Safe/Securite Intrinseque.
- 4. For entity installations, select a CSA or ATEX certified barrier that

satisfies the following:

Vmax ≥Voc; Ci + Ccable≤Ca;

Imax ≥Isc; Li+Lcable≤La

- For system installations, select a CSA or ATEX certified single channel barrier having the parameters of 28 Vdc (Max) and 300 ohms (Min).
- Barriers must be installed in accordance with manufacturer'S instructions
- 7. Exia is defined as intrinsically safe/securite intrinseque.

The PC45 series pickups are intrinsically safe electrical equipment and can be used in potentially explosive atmospheres. The apparatus must be installed with certified intrinsically safe equipment and the combination must be compatible with intrinsically safe rules and the electrical parameters in the below table.

CSA Entity Parameters

NOTE: Electrical specification V, and I, of the barriers installed with the pickup cannot exceed any of the following values.

| Vmax | Imax | Ci(F) | Li(mH) |
|------|------|--------|----------|
| 30 | 300 | 0 | 0 |
| | | | |
| 30 | 300 | 0 | 0 |
| | | | |
| | 30 | 30 300 | 30 300 0 |

ATEX Entity Parameters:

NOTE: Electrical specification U, I, and P of the barriers installed with the pickup cannot exceed any of the following values.

| Gas Group (ATEX) | Ui (V) Vmax | li (mA) Imax | Pi(W) | Ci(F) | Li(mH) |
|---------------------|----------------|-----------------|-------|-------|--------|
| IIC | 30 | 300 | .75 | 0 | 0 |

Maximum Ambient Temperature:

The maximum ambient temperature of the PC45 series is in accordance with the following temperature classes:


| T6 | T5 | T4 | T3 |
|--------------------|--------------------|---------------------|---------------------|
| -50°C to +80°C Max | -50°C to +95°C Max | -50°C to +130°C Max | -50°C to +175°C Max |

Marking:

The PC45 series shall be marked with either CSA or ATEX identification, or a combination label, as applicable and shall be identified by the part number, date code (AA BB), and Lot Identification number (YYYYYY).

WARNING: Do not separate when energized.

Installation Instructions For Intrinsically Safe Pickup Coils DMX and DRX Series



Notes:

- For CSA-NRTL Installations: Installation should be in accordance with ANSI/ISA RP12.6 "Installation of Intrinsically Safe Systems for Hazardous Locations" and the National Electric Code (ANSI/NFPA 70). For ATEX Installations: Installation should be in accordance with ATEX Directive for Installation of Intrinsically Safe systems in hazardous locations and in accordance with the relevant local Electric Codes.
- 2. For CSA Installations: Install in accordance with Canadian Electric Code Part 1. For ATEX Installations: Install in accordance with the relevant local Electric Code.
- 3. Pickup coils (with or without integral pre-amp) are suitable for hazardous locations Class I, Zone 0 and Class I, Division 1 (Groups as noted depend on the model). Pickup coils equipped with the "MS" type connector are only suitable for hazardous locations Class I, Division 1, Groups A, B, C, D; Class II, Division 1, Groups G, Class III and Coal Dust. Pickup coils with an "NPT" connector or "pigtail" leads can be used in hazardous locations Class I, Division 1, Groups A, B, C, D: Class II, Division 1, Groups E, F, G, and Class III. For ATEX installations, pickup coils are suitable for use in Ex ia IIC or IIB hazardous locations, where Exia is defined as Intrinsically Safe/Securite Intrinseque.
- 4. For entity installations, select a CSA or ATEX certified barrier that satisfies the following:

Ui/Vmax ≥Uo/Voc; Ci + Ccable≤Ca/Co Li/Imax ≥Io/Isc; Li+Lcable≤La/Lo

- For system installations, select a CSA or ATEX certified single channel barriers or one dual channel barrier where each channel has parameters of 28 Vdc (Max) and 600 ohms (Min), such as MTL-778 or Stahl 9002/77-280-094-00.
- Barriers must be installed in accordance with manufacturer's instructions.
- 7. Exia is defined as intrinsically safe/securite intrinseque.
- For system installations, select a CSA or ATEX certified single channel barriers or one dual channel barrier where each channel has parameters of 28 Vdc (Max) and 600 ohms (Min), such as MTL-778 or Stahl 9002/77-280-094-00.
- Barriers must be installed in accordance with manufacturer's instructions.
- 10. Exia is defined as intrinsically safe/securite intrinseque.

The amplified series of pickups are intrinsically safe electrical equipment and can be used in potentially explosive atmospheres. The apparatus must be installed with certified intrinsically safe the equipment and combination must be compatible with intrinsically safe rules and the electrical parameters in the below table.

| Class/Group (CSA) | Part Numbers | Ui/Vmax | li/Imax | Ci/Ci | Li/Li |
|---------------------------------------------------------------|----------------------------------------------------------------------------|---------|---------|-------------|---------------|
| Class 1, Zone 0 Group IIC/Class 1, DIV 1, Group A,B,C,D | DMX-XXX-1 DMX-XXX-2 DRX-XXX-1 DRX-XXX-2 | 30 VDC | 200 mA | 0 uF | 0.5 <u>mH</u> |
| Class 1, Zone 0 Group IIA/Class 1, DIV 1, Group D | DMX-XXX-3 DMX-XXX-4 DMX-XXX-5 DRX-XXX-4 DRX-XXX-5 DRX-XXX-3 | 30 VDC | 190 mA | 0 <u>uF</u> | 0.5 <u>mH</u> |

| Part Numbers | Group | Electrical Parameters |
|------------------------|-------|------------------------------------------------------|
| DMX-XXX-1 | IIC | Ui = 30V; Ii = 200mA; Pi = 0.75W; Ci = 0; Li = 0.5mH |
| DMX-XXX-2 DRX-XXX-1 | | |
| DRX-XXX-1 DRX-XXX-2 | | |
| DMX-XXX-3 | IIA | Ui = 30V; Ii = 190mA; Pi = 2.55W; Ci = 0; Li = 0.5mH |
| DMX-XXX-4 | | |
| DMX-XXX-5 | | |
| DRX-XXX-3 | | |
| DRX-XXX-4 | | |
| DRX-XXX-5 | | |

Maximum Ambient Temperature:

The maximum ambient temperature of the Amplified series is in accordance with the following temperature classes. Note: Refer to individual product specification sheet for temperature capabilities of specific model being used.

ATEX Certified Group IIC and IIA:

| Т2 | T4 |
|-----------------|----------------|
| -40°C to +125°C | -40°C to +51°C |

CSA Certified Group IIC:

| T2 | T4 |
|-----------------|----------------|
| -40°C to +125°C | -40°C to +51°C |

CSA Certified Group IIA:


| Т2 | T4 |
|-----------------|----------------|
| -40°C to +100°C | -40°C to +51°C |


Marking:


The amplified series of pickups and preamplifiers shall be marked with either CSA or ATEX identification, or a combination label, as applicable and shall be identified by the part number, date code (AA BB), and Lot Identification number (YYYYYY).

WARNING: Do not separate when energized.

RELATED DRAWINGS







| R C | | | | O | | + | | Œ |) | | | | < | g LL |
|----------------------------------|----------------|--------------------|--------------|----------|----------|------------|----------------|------------|------------|-----------|-------------|----------|------------------|----------|
| OMT. ASS | | L | . 622 | . 624 | . 524 | 1. 046 | 1. 36 | 1. 610 | 2. 067 | 2. 567 | 3.068 | 4. 062 | 759 | HOX-5005 |
| 1800000 80000000 800000000 | N ON | Д 4 | 2, 375 | 3, 031 | 3. 138 | 3. 281 | 3. 406 | 3. 488 | 3. 843 | 4. 093 | 4. 218 | 4. 9 0 0 | EPLACES 500-0159 | -XOH- |
| Ш | ı. | E 3 | 6. 612 | 6. 612 | 6. 937 | 7. 062 | 7, 187 | 7. 25 | 7. 625 | 7. 875 | 9. 000 | 6.75 | | S 33321 |
| 2046 NO. | ı z | E2 | 11. 00 | 11.00 | 11.00 | 11.187 | 11. 313 | 11.375 | 11, 75 | 12. 00 | 12, 125 | 12. 78 | | |
| | N H | П | 12.00 | 12.00 | 12.00 | 12.063 | 12.187 | 12, 25 | 12. 625 | 12, 875 | 13.00 | 12. 625 | | 2 2 |
| | FOR FLOWMETERS | (N. P. T. TAPERED) | 1/2 - 14 | 3/4 - 14 | 3/4 - 14 | 1 - 11 1/2 | 1 1/4 - 11 1/2 | 11/2-111/2 | 2 - 11 1/2 | 2 1/2 - 6 | B I D | • | | |
| | 1 1 | :0 | 1. 125 | 1. 125 | 1. 378 | 1. 625 | 1. 675 | 1. 675 | 2. 750 | 2, 882 | 9 9 | 4. 78 | | |
| | D MENS ONS | m | 1. 225 | 1. 375 | 1. 625 | 1. 75 | 1. 937 | 2. 187 | 2. 378 | 3, 031 | 3, 73 | 00 | | |
| | | ∢ | 2, 45 | 2.75 | 3, 23 | 3. 30 | 3. 873 | 4. 375 | 4.78 | 6.062 | 7. 50 | 10.00 | | |
| | NOMINAL | SIZE | 1/4 THRU 1/2 | 8/8 | 3/4 | - | 1.1/4 | 1 1/2 | м | 2 1/2 | n | • | | |
| | 0 | | | 0 | | | | 00 | | | | | ξ. | |

